



® **TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.**
Technical and Test Institute for Construction Prague, SOE

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Notified Body 1020

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1020 – CPR – 010044826

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR) and Commission Delegated Regulation (EU) No 568/2014, this certificate applies to the construction product:

Thermal insulation products for building equipment and industrial installations - Factory made flexible elastomeric foam (FEF) products

type / variation: see in Annex No.1 to this contract

placed on the market under the name or trade mark of

İZOCAM TİCARET ve SANAYİ A.Ş.

**Address: Altayçeşme Mahallesi, Çamlı Sokak, No:21, Kat:4-5, 34843,
Maltepe/İstanbul, Türkiye**

and produced in the manufacturing plant:

**ESKİŞEHİR ORGANİZE SANAYİ BÖLGESİ, 15. CADDE, ŞEHİTLER
BULVARI, 26110, OSB, ODUNPAZARI, ESKİŞEHİR**

verification of constancy of performance described in Annex ZA of the standard

EN 14304:2009+A1:2013


under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on **November 9th, 2021** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The stamp of the Notified Body 1020
Prague, 9th November, 2021




Ing. Iveta Jiroutová
Deputy manager of the Notified Body



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, SOE

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznámený subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Annex no. 1 to the Certificate no. 1020-CPR-010-044826

EN 14304:2009+A1:2013 - Thermal insulation products for building equipment and industrial installations - Factory made flexible elastomeric foam (FEF) products:

IZOCAMFLEX Rubber Foam Tube		
thickness [mm]	inner diameter [mm]	density [kg/m ³]
6	6 - 35	65
9	6 - 114	65
13	6 - 160	65
19	10 - 160	65
25	15 - 160	65

IZOCAMFLEX Rubber Foam Sheet	
thickness [mm]	density [kg/m ³]
6 - 25	65

The stamp of the Notified Body 1020
Prague, 9th November, 2021




Ing. Iveta Jiroutová
Deputy manager of the Notified Body