



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or T S E

BELGE NUMARASI REFERENCE NUMBER OF LICENCE	000134-TSE-12/02
BELGENİN İLK VERİLİŞ TARİHİ DATE OF FIRST ISSUE OF LICENCE	30.07.2012
BELGENİN SON GEÇERLİLİK TARİHİ LICENCE VALID UNTIL	30.07.2025
BELGE SAHİBİ KURULUŞUN ADI NAME OF THE LICENCE HOLDER	İZOCAM TİCARET VE SANAYİ ANONİM ŞİRKETİ
BELGE SAHİBİ KURULUŞUN ADRESİ ADDRESS OF THE LICENCE HOLDER	ALTAYÇEŞME MAH. ÇAMLI SK. NO:21 /4 MALTEPE İSTANBUL/TÜRKİYE
ÜRETİM YERİ ADI NAME OF THE MANUFACTURING PLACE	İZOCAM TİCARET VE SANAYİ ANONİM ŞİRKETİ
ÜRETİM YERİ ADRESİ ADDRESS OF THE MANUFACTURING PLACE	TARSUS CAMYÜNÜ ÜRETİM TESİSLERİ ADANA-MERSİN KARAYOLU ÜZERİ KONAKLAR KÖYÜ KELİ MEVKİİ TARSUS MERSİN / TÜRKİYE
İPTAL EDİLEN BELGE NUMARASI (Varsa) INDICATION OF SUPERSEDED LICENCE (if any)	000134-TSE-12/01
TESCİLLİ TİCARİ MARKASI REGISTERED TRADE MARK	izocam şekil
İLGİLİ TÜRK STANDARDI RELATED TURKISH STANDARD	TS EN 14303 / 18.02.2016
BELGE KAPSAMI SCOPE OF LICENCE	

THERMAL INSULATION PRODUCTS FOR BUILDING EQUIPMENT AND INDUSTRIAL INSTALLATIONS –
FACTORY MADE MINERAL WOOL (MW) PRODUCTS

1) PIPE SECTIONS (NOT FOR USE UNDER LOAD - UNCOATED)

- REACTION TO FIRE: A1

- THICKNESS CLASS: T8<150 mm, T9>150 mm

- THERMAL CONDUCTIVITY: λ (50 °C): 0.035 W/mK, λ (100 °C): 0.045 W/mK, λ (150 °C): 0.055 W/mK

2) BOARD (NOT FOR USE UNDER LOAD – ALUMINIUM FOIL AND GLASS TISSUE FACED

- REACTION TO FIRE: C-s1, d0

- THICKNESS CLASS: T5

- THERMAL CONDUCTIVITY: λ (40 0C) : 0.035 W/mK, λ (60 0C): 0.037 W/mK, λ (80 0C) : 0.040 W/mK

- COMMERCIAL MODEL: "İZOPAN"

e-imzalı/e-signed

02.08.2024

On Behalf Of The Head Of Certification Center
FATİH KURT

TSE ADANA CERTIFICATION DIRECTOR

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE * Address: Yakapınar Mah. D-400 Bulvarı No:174 Yüreğir * Telephone: 03224581940-41* Fax: 03224588243

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail :bmb@tse.org.tr , web : www.tse.org.tr





TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or T S E

(000134-TSE-12/02nolu belge devamı) : İZOCAM TİCARET VE SANAYİ ANONİM ŞİRKETİ
İLGİLİ TÜRK STANDARDI (RELATED TURKISH STANDARD) TS EN 14303 / 18.02.2016

3) BLANKET (NOT FOR USE UNDER LOAD – ALUMINIUM FOIL FACED)

- REACTION TO FIRE: C-s1, d0
- THICKNESS CLASS: T1
- THERMAL CONDUCTIVITY: $\lambda(10\text{ OC})$: 0.038 W/mK, $\lambda(25\text{ OC})$: 0.040 W/mK, $\lambda(50\text{ OC})$: 0.044 W/mK, $\lambda(75\text{ OC})$: 0.047 W/mK, $\lambda(100\text{ OC})$: 0.053 W/mK
- COMMERCIAL MODEL: "CKŞ 1"
(SCOPE CHANGE: 25.10.2022)

4) BOARD (NOT FOR USE UNDER LOAD - ALUMINIUM FOIL FACED)

- REACTION TO FIRE: C-s1, d0
- THICKNESS CLASS: T3
- THERMAL CONDUCTIVITY: $\lambda(10\text{ OC})$: 0.032 W/mK, $\lambda(25\text{ OC})$: 0.034 W/mK, $\lambda(50\text{ OC})$: 0.037 W/mK, $\lambda(75\text{ OC})$: 0.041 W/mK
- COMMERCIAL MODEL: "CKL 1"

5) BOARD (NOT FOR USE UNDER LOAD - ALUMINIUM FOIL FACED)

- REACTION TO FIRE: A2-s1, d0
- THICKNESS CLASS: T3
- THERMAL CONDUCTIVITY: $\lambda(10\text{ OC})$: 0.032 W/mK, $\lambda(25\text{ OC})$: 0.034 W/mK, $\lambda(50\text{ OC})$: 0.037 W/mK, $\lambda(75\text{ OC})$: 0.041 W/mK
- COMMERCIAL MODEL: "CKL 2"

6) BOARD (NOT FOR USE UNDER LOAD - ALUMINIUM FOIL FACED)

- REACTION TO FIRE: C-s1, d0
- THICKNESS CLASS: T5,
- THERMAL CONDUCTIVITY: $\lambda(10\text{ OC})$: 0.032 W/mK, $\lambda(25\text{ OC})$: 0.033 W/mK, $\lambda(50\text{ OC})$: 0.036 W/mK
- COMMERCIAL MODEL: "PRK"

7) PIPE (NOT FOR USE UNDER LOAD – ALUMINIUM FOIL FACED)

- REACTION TO FIRE: CL-s1, d0
- THICKNESS CLASS: T8<150 mm, T9>150 mm,
- THERMAL CONDUCTIVITY: $\lambda(25\text{ OC})$: 0.031 W/mK, $\lambda(50\text{ OC})$: 0.035 W/mK, $\lambda(75\text{ OC})$: 0.040 W/mK, $\lambda(100\text{ OC})$: 0.045 W/mK

8) BLANKET (NOT FOR USE UNDER LOAD. ACRYLENE FACED)

- REACTION TO FIRE: A2-s3, d0
- THICKNESS CLASS: T3,
- THERMAL CONDUCTIVITY: $\lambda(10\text{ OC})$: 0.034 W/mK, $\lambda(25\text{ OC})$: 0.036 W/mK, $\lambda(50\text{ OC})$: 0.041 W/mK, $\lambda(75\text{ OC})$: 0.044 W/mK
- COMMERCIAL MODEL: "DUCT LINER (IZOCAM AKUSTIK)"

e-imzalı/e-signed

02.08.2024

On Behalf Of The Head Of Certification Center
FATİH KURT

TSE ADANA CERTIFICATION DIRECTOR

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE * Address: Yakapınar Mah. D-400 Bulvarı No:174 Yüreğir * Telephone: 03224581940-41* Fax: 03224588243

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail :bmb@tse.org.tr , web : www.tse.org.tr

